ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
Bruhat Bengaluru Mahanagara Palike

No. EE/Ele/East/PR/ /2023-24

Office of the
Executive Engineer (Ele)
East Division, 16th floor
Public Utility Building,
M G road, Bangalore-560001.
Date: 01/12/2023

Tender corrigendum

Subject: Issuing corrigendum.

Ref: This office Tender notification No. BBMP/EE/ELE/East/TEND/ 03 /2023-24, dated 21/11/2023.

****

With reference to this office tender notification cited at reference above, the specification of item no.12 of tender schedule is modified as below.

Existing specification	Read as
Fabricating, supplying and erection of ... ms long hot dip Galvanized Conical hot dip Pole with BSEN 10025 grade S355JO steel plate for shaft, IS 2062 for base plate with door opening arrangements, including suitable boards, Bakelite sheet and MCBs as per IS specifications suitable to withstand the wind speed of 47 m/s for ..... m Pole in single section and single joint welded as per IS 9595/IS10178AWS having dimensions bottom..... mm , top ... mm with 3 mm thick, suitable base plate and 4Nos of.....long J bolts along with template and the Pole shall be hot dip galvanized in single dipping with not less than 65micron as per ASTM-A123 and 153 etc.,(excluding foundation) as per drawing appended. **8 m - Top 70 mm and Bottom 135 mm dia**	Fabricating, supplying and erection of ... ms long hot dip Galvanized Conical hot dip Pole with BSEN 10025 grade S355JO steel plate for shaft, IS 2062 for base plate with door opening arrangements, including suitable boards, Bakelite sheet and MCBs as per IS specifications suitable to withstand the wind speed of 47 m/s for ..... m Pole in single section and single joint welded as per IS 9595/IS10178AWS having dimensions bottom ..... mm , top ... mm with 3 mm thick, suitable base plate and 4Nos of.....long J bolts along with template and the Pole shall be hot dip galvanized in single dipping with not less than 65micron as per ASTM-A123 and 153 etc.,(excluding foundation) as per drawing appended. **8 m - Top 75 mm and Bottom 155 mm dia**

The other terms and conditions of tender and specifications of the schedule shall be unchanged.

Executive Engineer (Ele)
East-Zone
Bruhath Bengaluru Mahanagara Palike

Copy To.
1) Superintending Engineer(Ele), BBMP for kind information.
2) Office copy.